

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2021/SZ/ 157

Dated: 25/2/21

**FIRE SAFETY CERTIFICATE**

Certified that the **Sant Nirankari Public School** located at Avtar Enclave, Paschim Vihar, Delhi-110063 comprised of **Basement, Ground + Three upper floors** (old blocks G+ 2 & New Block B+G+3 both block are interconnected) was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2018/376 dated 07/03/2018. The premises was re-inspected by officer concern of this department on 17/02/2021 in the presence of Ms. Meenakshi Chugh (Vice-Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC-IV/Directorate of Education Circular. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi, and that the building/premises is fit for occupancy class **"Educational Building"** Group-B, as above with effect from 25.1.2021 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/2/21 at New Delhi by


  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone


Copy to: -

1. The Principal, Sant Nirankari Public School, Avtar Enclave, Paschim Vihar, Delhi- 63.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

  
NARINDER BATRA  
MANAGER  
Sant Nirankari Public School  
Affiliated to C.B.S.E. Upto Secondary Level  
Avtar Enclave, Paschim Vihar,  
New Delhi-110063

  
TANUJA MADAN  
Vice Principal  
Sant Nirankari Public School  
Affiliated to C.B.S.E Upto Secondary Level  
Avtar Enclave, Paschim Vihar,  
New Delhi-110063